



0000093256

ORIGINAL

SALLQUIST, DRUMMOND & O'CONNOR, P.C.
ATTORNEYS AT LAW
1430 East Missouri SUITE B-125
PHOENIX, ARIZONA 85014

RICHARD L. SALLQUIST

PHONE (602) 224-9222
FACSIMILE (602) 224-9366
E-MAIL dick@sd-law.com

February 3, 2009

HAND DELIVERY

Ms. Kay Kilger
Arizona Corporation Commission
Docket Control
1200 West Washington Street
Phoenix, Arizona 85007

Re: Oak Creek Water Company No.1; Docket Nos. W-01392A-07-0679; Decision No. 70622; Compliance Filing

Dear Ms. Kilger:

On January 26, 2009 Staff provided comments on the Compliance Tariff filed by the Company on November 27, 2008. Enclosed herewith are fifteen (15) copies of the three Sheets on which Staff had comments. Please substitute these Sheets in the November filing.

Staff did ask for explanations on two items on Sheet No. 6. The reference to items P and Q were typographical errors. The reference should have been to M and N. Those corrections have been made. The other inquiry was to "any member": in item B. This was proposed to prohibit a customer attempting, either intentionally or innocently, to avoid the off system monthly minimums by requesting service in the name of a household member who was not the prior customer. This clarification is probably not needed in the Company's service area, so it has been removed.

In the event you have any questions, or we can provide further information, please do not hesitate to contact the undersigned.

Arizona Corporation Commission

DOCKETED

FEB 03 2009

DOCKETED BY

Sincerely,

Richard L. Sallquist

AZ CORP COMMISSION
DOCKET CONTROL

2009 FEB -3 A 11:05

RECEIVED

Enclosure

Ms. Kay Kilger
February 3, 2009
Page 2

cc: Tayna Pitre
Kristin Wakeman

Applies to all **WATER** service areas

PART ONE

STATEMENT OF CHARGES
WATER SERVICE

III. ADDITIONAL CHARGES

A.	Establishment of Service Per Rule R14-2-403D (new customer charge, in addition to F, M and N below when applicable)	\$ 35.00
1.	If after hours	\$ 50.00
B.	Re-establishment of Service Per Rule R14-2-403D (same customer, same location within 12 months)	Note ¹
C.	Reconnection of Service (Delinquent) Per Rule R14-2-403D	\$ 50.00
D.	Charge for Moving Meter at Customer Request Per Rule R14-2-405B	Cost
E.	Minimum Deposit Requirement	Per Rule R14-2-403B
F.	Deposit Interest (per annum)	Per Rule R14-2-403B
G.	Meter Test (If correct)	\$ 30.00
H.	Meter Reread	\$ 20.00
I.	Charge for NSF Check	\$ 25.00

¹ Minimum Charge times number of months disconnected

Issued: November 27, 2008

Effective: December 1, 2008

ISSUED BY:

Dick Sitts, President
Oak Creek Water Company No. 1
90 Oak Creek Blvd.
Sedona, AZ 86336

DOCKET NO. W-01392A

Cancelling Sheet No.

Applies to all **WATER** service areas
PART TWO

STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE

I. CROSS-CONNECTION CONTROL

A. Purpose.

The purpose of this tariff is to protect Oak Creek Water Company No 1 ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-115.

B. Requirements.

In compliance with the Rules and Regulations of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-115 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-115.B or C applies.

Issued: November 27, 2008

Effective: December 1, 2008

ISSUED BY:

Dick Sitts, President
Oak Creek Water Company No. 1
90 Oak Creek Blvd.
Sedona, AZ 86336

DOCKET NO. W-01392A

Cancelling Sheet No.

Applies to all **WATER** service areas
PART TWO

STATEMENT OF TERMS AND CONDITIONS
WATER SERVICE

2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-115.D and E.

3. Subject to the provisions of A.A.C.R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.

4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.

6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:

Issued: November 27, 2008

Effective: December 1, 2008

ISSUED BY:

Dick Sitts, President
Oak Creek Water Company No. 1
90 Oak Creek Blvd.
Sedona, AZ 86336